



Element
Suite 100, 328 Ley Road
Fort Wayne, Indiana
46825, United States

T: +1 (260) 471-7000
E: Info.FortWayne@element.com
W: www.element.com

June 4, 2025

Aija Putelis
120 Water Audit
PO Box 604
ZIONSVILLE, IN 46077

RE: IFA LIF: Area Five Agency Head Start

Dear Aija Putelis:

Lot Id: 226504

Element Materials Technology – Fort Wayne received 50 sample(s) on 5/20/2025 for the analyses presented in the following report.

In accordance with your instructions, a laboratory of Element Materials Technology Fort Wayne LLC either conducted or subcontracted these analyses. Subcontracted analyses will be identified in an accompanying case narrative and any associated report(s) will be attached in full. Unless otherwise noted in the case narrative, all analyses were conducted using approved methodologies. Reported results relate only to the items tested.

Estimated uncertainty is available upon request. This report shall not be reproduced, except in full, without the written approval of the laboratory.

If you have any questions regarding these test results, please feel free to call.

Sincerely,

Megan Krauskopf
Senior Project Manager
Suite 100, 328 Ley Road,
Fort Wayne, IN 46825

Accreditation

TNI:2016 (Florida)
ISO 17025:2017 (A2LA)
Indiana – Fort Wayne
Indiana – Fort Wayne
Indiana – Columbus
Indiana – South Bend

Cert #

E871168
6190.02
C-02-03
M-02-05
M-03-02
M-71-02

Accreditation

Louisiana
Michigan
South Dakota
Tennessee

Cert #

235913
9030
--
04911

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: IFA LIF: Area Five Agency Head Start	Lot ID: 226504
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By:	Project Location:	Date Received: May 20, 2025
Company:	LSD:	Date Reported: Jun 4, 2025
	P.O.: IFA Lead in Facilities	Report Number: 329089
	Proj. Acct. code: IFA Lead in Facilities	Report Type: Final Report

Reference Number 226504-1		Sample Date 2025-05-17 06:19			
Sample Description 101 Initial		Sample Matrix Drinking Water			
Analyte	Result	Units	Qual DF Detection Limit	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS					
Lead	Total	0.46	µg/L	1 0.20	Jun 03, 2025 10:56 FR

Reference Number 226504-2		Sample Date 2025-05-17 06:22			
Sample Description 101 Flush		Sample Matrix Drinking Water			
Analyte	Result	Units	Qual DF Detection Limit	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS					
Lead	Total	<0.20	µg/L	1 0.20	Jun 03, 2025 10:56 FR

Reference Number 226504-3		Sample Date 2025-05-17 06:24			
Sample Description 102 Initial		Sample Matrix Drinking Water			
Analyte	Result	Units	Qual DF Detection Limit	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS					
Lead	Total	<0.20	µg/L	1 0.20	Jun 03, 2025 10:56 FR

Reference Number 226504-4		Sample Date 2025-05-17 06:27			
Sample Description 103 Initial		Sample Matrix Drinking Water			
Analyte	Result	Units	Qual DF Detection Limit	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS					
Lead	Total	4.29	µg/L	1 0.20	Jun 03, 2025 10:56 FR

Reference Number 226504-5		Sample Date 2025-05-17 06:28			
Sample Description 104 Initial		Sample Matrix Drinking Water			
Analyte	Result	Units	Qual DF Detection Limit	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS					
Lead	Total	1.69	µg/L	1 0.20	Jun 03, 2025 10:56 FR

Reference Number 226504-6		Sample Date 2025-05-17 06:29			
Sample Description 105 Initial		Sample Matrix Drinking Water			
Analyte	Result	Units	Qual DF Detection Limit	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS					
Lead	Total	1.10	µg/L	1 0.20	Jun 03, 2025 10:56 FR

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: IFA LIF: Area Five Agency Head Start	Lot ID: 226504
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By:	Project Location:	Date Received: May 20, 2025
Company:	LSD:	Date Reported: Jun 4, 2025
	P.O.: IFA Lead in Facilities	Report Number: 329089
	Proj. Acct. code: IFA Lead in Facilities	Report Type: Final Report

Reference Number 226504-7		Sample Date 2025-05-17 06:30			
Sample Description 106 Initial		Sample Matrix Drinking Water			
Analyte	Result	Units	Qual DF Detection Limit	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS					
Lead	Total	0.42	µg/L	1 0.20	Jun 03, 2025 10:56 FR
Reference Number 226504-8		Sample Date 2025-05-17 06:32			
Sample Description 106 Flush		Sample Matrix Drinking Water			
Analyte	Result	Units	Qual DF Detection Limit	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS					
Lead	Total	0.22	µg/L	1 0.20	Jun 03, 2025 10:56 FR
Reference Number 226504-9		Sample Date 2025-05-17 06:35			
Sample Description 107 Initial		Sample Matrix Drinking Water			
Analyte	Result	Units	Qual DF Detection Limit	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS					
Lead	Total	2.57	µg/L	1 0.20	Jun 03, 2025 10:56 FR
Reference Number 226504-10		Sample Date 2025-05-17 06:37			
Sample Description 108 Initial		Sample Matrix Drinking Water			
Analyte	Result	Units	Qual DF Detection Limit	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS					
Lead	Total	1.37	µg/L	1 0.20	Jun 03, 2025 10:56 FR
Reference Number 226504-11		Sample Date 2025-05-17 06:37			
Sample Description 108 Flush		Sample Matrix Drinking Water			
Analyte	Result	Units	Qual DF Detection Limit	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS					
Lead	Total	0.29	µg/L	1 0.20	Jun 03, 2025 10:56 FR
Reference Number 226504-12		Sample Date 2025-05-17 06:44			
Sample Description 109 Initial		Sample Matrix Drinking Water			
Analyte	Result	Units	Qual DF Detection Limit	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS					
Lead	Total	7.68	µg/L	1 0.20	Jun 03, 2025 10:56 FR

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: IFA LIF: Area Five Agency Head Start	Lot ID: 226504
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By:	Project Location:	Date Received: May 20, 2025
Company:	LSD:	Date Reported: Jun 4, 2025
	P.O.: IFA Lead in Facilities	Report Number: 329089
	Proj. Acct. code: IFA Lead in Facilities	Report Type: Final Report

Reference Number 226504-13		Sample Date 2025-05-17 06:46			
Sample Description 110 Initial		Sample Matrix Drinking Water			
Analyte	Result	Units	Qual DF Detection Limit	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS					
Lead	Total	1.89	µg/L	1 0.20	Jun 03, 2025 10:56 FR
Reference Number 226504-14		Sample Date 2025-05-17 06:47			
Sample Description 110 Flush		Sample Matrix Drinking Water			
Analyte	Result	Units	Qual DF Detection Limit	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS					
Lead	Total	0.32	µg/L	1 0.20	Jun 03, 2025 10:56 FR
Reference Number 226504-15		Sample Date 2025-05-17 06:48			
Sample Description 111 Initial		Sample Matrix Drinking Water			
Analyte	Result	Units	Qual DF Detection Limit	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS					
Lead	Total	1.26	µg/L	1 0.20	Jun 03, 2025 10:56 FR
Reference Number 226504-16		Sample Date 2025-05-17 06:49			
Sample Description 112 Initial		Sample Matrix Drinking Water			
Analyte	Result	Units	Qual DF Detection Limit	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS					
Lead	Total	3.19	µg/L	1 0.20	Jun 03, 2025 10:56 FR
Reference Number 226504-17		Sample Date 2025-05-17 06:51			
Sample Description 113 Initial		Sample Matrix Drinking Water			
Analyte	Result	Units	Qual DF Detection Limit	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS					
Lead	Total	0.81	µg/L	1 0.20	Jun 03, 2025 10:56 FR
Reference Number 226504-18		Sample Date 2025-05-17 06:53			
Sample Description 114 Initial		Sample Matrix Drinking Water			
Analyte	Result	Units	Qual DF Detection Limit	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS					
Lead	Total	0.87	µg/L	1 0.20	Jun 03, 2025 10:56 FR

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: IFA LIF: Area Five Agency Head Start	Lot ID: 226504
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By:	Project Location:	Date Received: May 20, 2025
Company:	LSD:	Date Reported: Jun 4, 2025
	P.O.: IFA Lead in Facilities	Report Number: 329089
	Proj. Acct. code: IFA Lead in Facilities	Report Type: Final Report

Reference Number 226504-19		Sample Date 2025-05-17 06:56				
Sample Description 114 Flush		Sample Matrix Drinking Water				
Analyte	Result	Units	Qual DF	Detection Limit	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS						
Lead	Total	<0.20	µg/L	1	0.20	Jun 03, 2025 10:56 FR
Reference Number 226504-20		Sample Date 2025-05-17 06:56				
Sample Description 115 Initial		Sample Matrix Drinking Water				
Analyte	Result	Units	Qual DF	Detection Limit	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS						
Lead	Total	2.62	µg/L	1	0.20	Jun 03, 2025 10:56 FR
Reference Number 226504-21		Sample Date 2025-05-17 06:58				
Sample Description 116 Initial		Sample Matrix Drinking Water				
Analyte	Result	Units	Qual DF	Detection Limit	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS						
Lead	Total	2.32	µg/L	1	0.20	Jun 03, 2025 10:56 FR
Reference Number 226504-22		Sample Date 2025-05-17 07:01				
Sample Description 117 Initial		Sample Matrix Drinking Water				
Analyte	Result	Units	Qual DF	Detection Limit	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS						
Lead	Total	1.81	µg/L	1	0.20	Jun 03, 2025 10:56 FR
Reference Number 226504-23		Sample Date 2025-05-17 07:02				
Sample Description 118 Initial		Sample Matrix Drinking Water				
Analyte	Result	Units	Qual DF	Detection Limit	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS						
Lead	Total	1.27	µg/L	1	0.20	Jun 03, 2025 10:56 FR
Reference Number 226504-24		Sample Date 2025-05-17 07:03				
Sample Description 118 Flush		Sample Matrix Drinking Water				
Analyte	Result	Units	Qual DF	Detection Limit	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS						
Lead	Total	0.38	µg/L	1	0.20	Jun 03, 2025 10:56 FR

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: IFA LIF: Area Five Agency Head Start	Lot ID: 226504
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By:	Project Location:	Date Received: May 20, 2025
Company:	LSD:	Date Reported: Jun 4, 2025
	P.O.: IFA Lead in Facilities	Report Number: 329089
	Proj. Acct. code: IFA Lead in Facilities	Report Type: Final Report

Reference Number 226504-25		Sample Date 2025-05-17 07:04					
Sample Description 119 Initial		Sample Matrix Drinking Water					
Analyte	Result	Units	Qual	DF	Detection Limit	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS							
Lead	Total	1.57	µg/L		1	0.20	Jun 03, 2025 10:56 FR
Reference Number 226504-26		Sample Date 2025-05-17 07:06					
Sample Description 120 Initial		Sample Matrix Drinking Water					
Analyte	Result	Units	Qual	DF	Detection Limit	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS							
Lead	Total	0.83	µg/L		1	0.20	Jun 03, 2025 10:56 FR
Reference Number 226504-27		Sample Date 2025-05-17 07:08					
Sample Description 121 Initial		Sample Matrix Drinking Water					
Analyte	Result	Units	Qual	DF	Detection Limit	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS							
Lead	Total	1.20	µg/L		1	0.20	Jun 03, 2025 10:56 FR
Reference Number 226504-28		Sample Date 2025-05-17 07:09					
Sample Description 122 Initial		Sample Matrix Drinking Water					
Analyte	Result	Units	Qual	DF	Detection Limit	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS							
Lead	Total	0.50	µg/L		1	0.20	Jun 03, 2025 10:56 FR
Reference Number 226504-29		Sample Date 2025-05-17 07:11					
Sample Description 122 Flush		Sample Matrix Drinking Water					
Analyte	Result	Units	Qual	DF	Detection Limit	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS							
Lead	Total	<0.20	µg/L		1	0.20	Jun 03, 2025 10:56 FR
Reference Number 226504-30		Sample Date 2025-05-17 07:13					
Sample Description 123 Initial		Sample Matrix Drinking Water					
Analyte	Result	Units	Qual	DF	Detection Limit	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS							
Lead	Total	2.16	µg/L		1	0.20	Jun 03, 2025 10:56 FR

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: IFA LIF: Area Five Agency Head Start	Lot ID: 226504
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By:	Project Location:	Date Received: May 20, 2025
Company:	LSD:	Date Reported: Jun 4, 2025
	P.O.: IFA Lead in Facilities	Report Number: 329089
	Proj. Acct. code: IFA Lead in Facilities	Report Type: Final Report

Reference Number 226504-31		Sample Date 2025-05-17 07:20				
Sample Description 124 Initial		Sample Matrix Drinking Water				
Analyte	Result	Units	Qual DF	Detection Limit	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS						
Lead	Total	1.99	µg/L	1	0.20	Jun 03, 2025 10:56 FR
Reference Number 226504-32		Sample Date 2025-05-17 07:21				
Sample Description 125 Initial		Sample Matrix Drinking Water				
Analyte	Result	Units	Qual DF	Detection Limit	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS						
Lead	Total	0.60	µg/L	1	0.20	Jun 03, 2025 10:56 FR
Reference Number 226504-33		Sample Date 2025-05-17 07:23				
Sample Description 126 Initial		Sample Matrix Drinking Water				
Analyte	Result	Units	Qual DF	Detection Limit	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS						
Lead	Total	0.37	µg/L	1	0.20	Jun 03, 2025 10:56 FR
Reference Number 226504-34		Sample Date 2025-05-17 07:24				
Sample Description 126 Flush		Sample Matrix Drinking Water				
Analyte	Result	Units	Qual DF	Detection Limit	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS						
Lead	Total	<0.20	µg/L	1	0.20	Jun 03, 2025 10:56 FR
Reference Number 226504-35		Sample Date 2025-05-17 07:25				
Sample Description 127 Initial		Sample Matrix Drinking Water				
Analyte	Result	Units	Qual DF	Detection Limit	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS						
Lead	Total	1.51	µg/L	1	0.20	Jun 03, 2025 10:56 FR
Reference Number 226504-36		Sample Date 2025-05-17 07:31				
Sample Description 128 Initial		Sample Matrix Drinking Water				
Analyte	Result	Units	Qual DF	Detection Limit	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS						
Lead	Total	4.06	µg/L	1	0.20	Jun 03, 2025 10:56 FR

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: IFA LIF: Area Five Agency Head Start	Lot ID: 226504
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By:	Project Location:	Date Received: May 20, 2025
Company:	LSD:	Date Reported: Jun 4, 2025
	P.O.: IFA Lead in Facilities	Report Number: 329089
	Proj. Acct. code: IFA Lead in Facilities	Report Type: Final Report

Reference Number 226504-37		Sample Date 2025-05-17 07:33			
Sample Description 129 Initial		Sample Matrix Drinking Water			
Analyte	Result	Units	Qual DF Detection Limit	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS					
Lead	Total	1.16	µg/L	1 0.20	Jun 03, 2025 10:56 FR
Reference Number 226504-38		Sample Date 2025-05-17 07:34			
Sample Description 130 Initial		Sample Matrix Drinking Water			
Analyte	Result	Units	Qual DF Detection Limit	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS					
Lead	Total	1.01	µg/L	1 0.20	Jun 03, 2025 10:56 FR
Reference Number 226504-39		Sample Date 2025-05-17 07:36			
Sample Description 130 Flush		Sample Matrix Drinking Water			
Analyte	Result	Units	Qual DF Detection Limit	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS					
Lead	Total	0.31	µg/L	1 0.20	Jun 03, 2025 10:56 FR
Reference Number 226504-40		Sample Date 2025-05-17 07:37			
Sample Description 131 Initial		Sample Matrix Drinking Water			
Analyte	Result	Units	Qual DF Detection Limit	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS					
Lead	Total	1.11	µg/L	1 0.20	Jun 03, 2025 10:56 FR
Reference Number 226504-41		Sample Date 2025-05-17 07:39			
Sample Description 132 Initial		Sample Matrix Drinking Water			
Analyte	Result	Units	Qual DF Detection Limit	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS					
Lead	Total	3.18	µg/L	1 0.20	Jun 03, 2025 10:56 FR
Reference Number 226504-42		Sample Date 2025-05-17 07:41			
Sample Description 133 Initial		Sample Matrix Drinking Water			
Analyte	Result	Units	Qual DF Detection Limit	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS					
Lead	Total	1.24	µg/L	1 0.20	Jun 03, 2025 10:56 FR

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: IFA LIF: Area Five Agency Head Start	Lot ID: 226504
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By:	Project Location:	Date Received: May 20, 2025
Company:	LSD:	Date Reported: Jun 4, 2025
	P.O.: IFA Lead in Facilities	Report Number: 329089
	Proj. Acct. code: IFA Lead in Facilities	Report Type: Final Report

Reference Number 226504-43		Sample Date 2025-05-17 07:42			
Sample Description 134 Initial		Sample Matrix Drinking Water			
Analyte	Result	Units	Qual DF Detection Limit	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS					
Lead	Total	0.54	µg/L	1 0.20	Jun 03, 2025 10:56 FR
Reference Number 226504-44		Sample Date 2025-05-17 07:43			
Sample Description 134 Flush		Sample Matrix Drinking Water			
Analyte	Result	Units	Qual DF Detection Limit	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS					
Lead	Total	0.43	µg/L	1 0.20	Jun 03, 2025 10:56 FR
Reference Number 226504-45		Sample Date 2025-05-17 07:44			
Sample Description 135 Initial		Sample Matrix Drinking Water			
Analyte	Result	Units	Qual DF Detection Limit	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS					
Lead	Total	1.66	µg/L	1 0.20	Jun 03, 2025 10:56 FR
Reference Number 226504-46		Sample Date 2025-05-17 07:47			
Sample Description 136 Initial		Sample Matrix Drinking Water			
Analyte	Result	Units	Qual DF Detection Limit	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS					
Lead	Total	1.07	µg/L	1 0.20	Jun 03, 2025 10:56 FR
Reference Number 226504-47		Sample Date 2025-05-17 07:48			
Sample Description 137 Initial		Sample Matrix Drinking Water			
Analyte	Result	Units	Qual DF Detection Limit	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS					
Lead	Total	1.29	µg/L	1 0.20	Jun 03, 2025 10:56 FR
Reference Number 226504-48		Sample Date 2025-05-17 07:49			
Sample Description 138 Initial		Sample Matrix Drinking Water			
Analyte	Result	Units	Qual DF Detection Limit	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS					
Lead	Total	0.46	µg/L	1 0.20	Jun 03, 2025 10:56 FR

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: IFA LIF: Area Five Agency Head Start	Lot ID: 226504
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By:	Project Location:	Date Received: May 20, 2025
Company:	LSD:	Date Reported: Jun 4, 2025
	P.O.: IFA Lead in Facilities	Report Number: 329089
	Proj. Acct. code: IFA Lead in Facilities	Report Type: Final Report

Reference Number 226504-49		Sample Date 2025-05-17 07:50					
Sample Description 138 Flush		Sample Matrix Drinking Water					
Analyte	Result	Units	Qual	DF	Detection Limit	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS							
Lead	Total	0.27	µg/L		1	0.20	Jun 03, 2025 10:56 FR

Reference Number 226504-50		Sample Date 2025-05-17 07:51					
Sample Description 139 Initial		Sample Matrix Drinking Water					
Analyte	Result	Units	Qual	DF	Detection Limit	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS							
Lead	Total	1.67	µg/L		1	0.20	Jun 03, 2025 10:56 FR

Approved by:



Megan Krauskopf
Senior Project Manager

Data have been validated by Analytical Quality Control and Element's Integrated Data Validation System (IDVS).

Generation and distribution of the report, and approval by the digitized signature above, are performed through a secure and controlled automatic process.

Methodology and Notes

Bill To:	120 Water Audit	Project ID:	IFA LIF: Area Five	Lot ID:	226504
	PO Box 604		Agency Head Start	Control Number:	
	ZIONSVILLE, IN, United States	Project Name:		Date Received:	May 20, 2025
	46077	Project Location:		Date Reported:	Jun 4, 2025
Attn:	Accounts Payable	LSD:		Report Number:	329089
Sampled By:		P.O.:	IFA Lead in Facilities	Report Type:	Final Report
Company:		Proj. Acct. code:	IFA Lead in Facilities		

Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
Metals ICP-MS Total in water	EPA	Trace Elements in Waters and Wastes by Inductively Coupled Plasma-Mass Spectrometry, E200.8	Jun 03, 2025	Fort Wayne

References

EPA	United States Environmental Protection Agency
-----	---

Please direct any inquiries regarding this report to our Client Services group.

Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.



Element
Suite 100, 328 Ley Road
Fort Wayne, Indiana
46825, United States

T: +1 (260) 471-7000
E: Info.FortWayne@element.com
W: www.element.com

Report Transmission Cover Page

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: IFA LIF: Area Five Agency Head Start	Lot ID: 226504
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By:	Project Location:	Date Received: May 20, 2025
Company:	LSD:	Date Reported: Jun 4, 2025
	P.O.: IFA Lead in Facilities	Report Number: 329089
	Proj. Acct. code: IFA Lead in Facilities	Report Type: Final Report

Contact	Company	Address
Aija Putelis	120 Water Audit	PO Box 604 ZIONSVILLE, IN 46077 Phone: (317) 586-1663 Fax: Email: aija.putelis@120water.com
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email - Merge	PDF	COC / Test Report
Megan Krauskopf	120 Water Audit	Fort Wayne, IN Phone: (260) 471-7000 Fax: Email: megan.krauskopf@element.com
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email	Standard Crosstab Without Tabs	Test Report
Results 120wateraudit	120 Water Audit	PO Box 604 ZIONSVILLE, IN 46077 Phone: (000) 000-0000 Fax: Email: results@120water.com
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email - Merge	PDF	COC / Test Report
Support	120 Water Audit	PO Box 604 ZIONSVILLE, IN 46077 Phone: (317) 331-3030 Fax: Email: sampling@120water.com
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email - Merge	PDF	COC / Test Report

The information contained on this and all other pages transmitted, is intended for the addressee only and is considered confidential.
If the reader is not the intended recipient, you are hereby notified that any use, dissemination, distribution or copy of this transmission is strictly prohibited.
If you receive this transmission by error, or if this transmission is not satisfactory, please notify us by telephone.

Released 5-22-25

226504

Chain of Custody

Chain of Custody (CoC) Instructions: The CoC is an official record that accounts for your water samples and must be filled out. You can either collect samples with your 120Water account or by using this form. If you collect samples within your 120Water account, simply fill out section 1 and use return to lab shipping label included in kit and drop kit off at post office. If you use this form to collect samples, fill out both sections 1 and 2, make sure to write down the time you collected each sample and then use return to lab shipping label included in kit and drop kit off at post office. Have questions? Call 800.674.7961 or email support@120water.com

Facility Name: Area Five Agency Head Start

Facility ID: N/A

Sample Event ID: 12943

Account ID: 1- IFA LIF

SECTION 1 MUST BE COMPLETED (even if you collect samples with your 120Water account)

Sampling Date (MM/DD/YYYY): 05/17/2025

Sample Collector's Email: Jhole@areafive.com

Sample Collector(s) Name (s) (Please Print):

Sample Collector's Phone: 574-383-0214

Sample Collector(s) Signature:

When was water last used in the building?

DATE: 5/16/25

TIME: 4:00pm

Did you collect samples within your 120Water account?



YES



NO, I will use this form

SECTION 2 (NEXT PAGE) MUST BE COMPLETED IF YOU USE THIS FORM TO COLLECT SAMPLES

If you use this form to collect samples (instead of collecting within the 120Water platform) you must write the time each sample was collected in Section 2.

Lab Use Only

RECEIVED IN LAB BY:

DATE:

TIME:

Matrix: DW-Lead

Analyte: Total Lead

WORK ORDER:

Lab Reporting: Email EDD to
results@120water.com

Sample Type: Grab

19.3°C
IR-023

Lot: 226504 COC

120 Water Audit



16

226504

Section 2 (Starting Here) Must be Completed if you use this Form to Collect Samples -

Sample Code	Fixture Code	Sample Type	Location	Location Description	Fixture Type	Time Sample Collected	Notes
477770	101	Initial	Staff kitchen	Faucet in staff kitchen	Faucet, Cold		
477771	101	Flush	Staff kitchen	Faucet in staff kitchen	Faucet, Cold		
477772	102	Initial	Staff kitchen	Next to fridge in staff kitchen	Bottle Filler		
477773	103	Initial	Classroom 25	Bathroom faucet	Faucet, Cold		
477774	104	Initial	Classroom 25	Staff faucet	Faucet, Cold		
477775	105	Initial	Classroom 25	Bubbler on kids sink	Bubbler		
477776	106	Initial	Classroom 25	Faucet on kids sink	Faucet, Cold		
477777	106	Flush	Classroom 25	Faucet on kids sink	Faucet, Cold		
477778	107	Initial	Room 26	Faucet in break room	Faucet, Cold		
477779	108	Initial	Room 30	Kitchen food prep faucet	Faucet, Cold		
477780	108	Flush	Room 30	Kitchen food prep faucet	Faucet, Cold		

226504

Section 2 (Starting Here) Must be Completed if you use this Form to Collect Samples -

Sample Code	Fixture Code	Sample Type	Location	Location Description	Fixture Type	Time Sample Collected	Notes
477781	109	Initial	Room 34	Staff faucet	Faucet, Cold		
477782	110	Initial	Room 34	Faucet on kids sink	Faucet, Cold		
477783	110	Flush	Room 34	Faucet on kids sink	Faucet, Cold		
477784	111	Initial	Room 34	Bubbler on kids sink	Bubbler		
477785	112	Initial	Room 34	Faucet in kids bathroom	Faucet, Cold		
477786	113	Initial	Classroom 33	Staff faucet	Faucet, Cold		
477787	114	Initial	Classroom 33	Faucet on kids sink	Faucet, Cold		
477788	114	Flush	Classroom 33	Faucet on kids sink	Faucet, Cold		
477789	115	Initial	Classroom 33	Faucet in kids bathroom	Faucet, Cold		
477790	116	Initial	Classroom 32	Faucet in kids bathroom	Faucet, Cold		
477791	117	Initial	Classroom 32	Bubbler on kids sink	Bubbler		

226504

Section 2 (Starting Here) Must be Completed if you use this Form to Collect Samples -

Sample Code	Fixture Code	Sample Type	Location	Location Description	Fixture Type	Time Sample Collected	Notes
477792	118	Initial	Classroom 32	Faucet on kids sink	Faucet, Cold		
477793	118	Flush	Classroom 32	Faucet on kids sink	Faucet, Cold		
477794	119	Initial	Classroom 32	Staff faucet	Faucet, Cold		
477795	120	Initial	Classroom 31	Staff faucet	Faucet, Cold		
477796	121	Initial	Classroom 31	Bubbler on kids sink	Bubbler		
477797	122	Initial	Classroom 31	Faucet on kids sink	Faucet, Cold		
477798	122	Flush	Classroom 31	Faucet on kids sink	Faucet, Cold		
477799	123	Initial	Classroom 31	Faucet in kids bathroom	Faucet, Cold		
477800	124	Initial	Classroom 29	Faucet in kids bathroom	Faucet, Cold		
477801	125	Initial	Classroom 29	Bubbler on kids sink	Bubbler		
477802	126	Initial	Classroom 29	Faucet on kids sink	Faucet, Cold		

226504

Section 2 (Starting Here) Must be Completed if you use this Form to Collect Samples -

Sample Code	Fixture Code	Sample Type	Location	Location Description	Fixture Type	Time Sample Collected	Notes
477803	126	Flush	Classroom 29	Faucet on kids sink	Faucet, Cold		
477804	127	Initial	Classroom 29	Staff faucet	Faucet, Cold		
477805	128	Initial	Classroom 15	Faucet in kids bathroom	Faucet, Cold		
477806	129	Initial	Classroom 15	Bubbler on kids sink	Bubbler		
477807	130	Initial	Classroom 15	Faucet on kids sink	Faucet, Cold		
477808	130	Flush	Classroom 15	Faucet on kids sink	Faucet, Cold		
477809	131	Initial	Classroom 15	Staff faucet	Faucet, Cold		
477810	132	Initial	Classroom 13	Faucet in kids bathroom	Faucet, Cold		
477811	133	Initial	Classroom 13	Bubbler on kids faucet	Bubbler		
477812	134	Initial	Classroom 13	Faucet on kids sink	Faucet, Cold		
477813	134	Flush	Classroom 13	Faucet on kids sink	Faucet, Cold		

226504

Section 2 (Starting Here) Must be Completed if you use this Form to Collect Samples -

Sample Code	Fixture Code	Sample Type	Location	Location Description	Fixture Type	Time Sample Collected	Notes
477814	135	Initial	Classroom 13	Staff faucet	Faucet, Cold		
477815	136	Initial	Classroom 12	Staff faucet	Faucet, Cold		
477816	137	Initial	Classroom 12	Bubbler in kids sink	Bubbler		
477817	138	Initial	Classroom 12	Faucet on kids sink	Faucet, Cold		
477818	138	Flush	Classroom 12	Faucet on kids sink	Faucet, Cold		
477819	139	Initial	Classroom 12	Faucet in kids bathroom	Faucet, Cold		