



Element  
Suite 100, 328 Ley Road  
Fort Wayne, Indiana  
46825, United States

T: +1 (260) 471-7000  
E: Info.FortWayne@element.com  
W: www.element.com

May 28, 2025

Aija Putelis  
120 Water Audit  
PO Box 604  
ZIONSVILLE, IN 46077

RE: IFA LIF: Area Five Agency Rochester Head Start

Dear Aija Putelis:

Lot Id: 225484

Element Materials Technology – Fort Wayne received 13 sample(s) on 5/13/2025 for the analyses presented in the following report.

In accordance with your instructions, a laboratory of Element Materials Technology Fort Wayne LLC either conducted or subcontracted these analyses. Subcontracted analyses will be identified in an accompanying case narrative and any associated report(s) will be attached in full. Unless otherwise noted in the case narrative, all analyses were conducted using approved methodologies. Reported results relate only to the items tested.

Estimated uncertainty is available upon request. This report shall not be reproduced, except in full, without the written approval of the laboratory.

If you have any questions regarding these test results, please feel free to call.

Sincerely,

Megan Krauskopf  
Senior Project Manager  
Suite 100, 328 Ley Road,  
Fort Wayne, IN 46825

**Accreditation**

TNI:2016 (Florida)  
ISO 17025:2017 (A2LA)  
Indiana – Fort Wayne  
Indiana – Fort Wayne  
Indiana – Columbus  
Indiana – South Bend

**Cert #**

E871168  
6190.02  
C-02-03  
M-02-05  
M-03-02  
M-71-02

**Accreditation**

Louisiana  
Michigan  
South Dakota  
Tennessee

**Cert #**

235913  
9030  
--  
04911

## Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: IFA LIF: Area Five Agency Rochester Head Start	Lot ID: <b>225484</b>
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By:	Project Location:	Date Received: May 13, 2025
Company:	LSD:	Date Reported: May 28, 2025
	P.O.:	Report Number: 328038
	Proj. Acct. code: IFA Lead in Facilities	Report Type: Final Report

Reference Number 225484-1		Sample Date 2025-05-09 06:06					
Sample Description 101 Initial		Sample Matrix Drinking Water					
Analyte	Result	Units	Qual	DF	Detection Limit	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS							
Lead	Total	3.86	µg/L		1	0.20	May 27, 2025 07:35 FR

Reference Number 225484-2		Sample Date 2025-05-09 06:08					
Sample Description 102 Initial		Sample Matrix Drinking Water					
Analyte	Result	Units	Qual	DF	Detection Limit	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS							
Lead	Total	0.30	µg/L		1	0.20	May 27, 2025 07:35 FR

Reference Number 225484-3		Sample Date 2025-05-09 06:09					
Sample Description 102 Flush		Sample Matrix Drinking Water					
Analyte	Result	Units	Qual	DF	Detection Limit	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS							
Lead	Total	1.32	µg/L		1	0.20	May 27, 2025 07:35 FR

Reference Number 225484-4		Sample Date 2025-05-09 06:12					
Sample Description 103 Initial		Sample Matrix Drinking Water					
Analyte	Result	Units	Qual	DF	Detection Limit	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS							
Lead	Total	<0.20	µg/L		1	0.20	May 27, 2025 07:35 FR

Reference Number 225484-5		Sample Date 2025-05-09 06:15					
Sample Description 103 Flush		Sample Matrix Drinking Water					
Analyte	Result	Units	Qual	DF	Detection Limit	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS							
Lead	Total	<0.20	µg/L		1	0.20	May 27, 2025 07:35 FR

Reference Number 225484-6		Sample Date 2025-05-09 06:15					
Sample Description 104 Initial		Sample Matrix Drinking Water					
Analyte	Result	Units	Qual	DF	Detection Limit	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS							
Lead	Total	1.60	µg/L		1	0.20	May 27, 2025 07:35 FR

## Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: IFA LIF: Area Five Agency Rochester Head Start	Lot ID: <b>225484</b>
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By:	Project Location:	Date Received: May 13, 2025
Company:	LSD:	Date Reported: May 28, 2025
	P.O.:	Report Number: 328038
	Proj. Acct. code: IFA Lead in Facilities	Report Type: Final Report

Reference Number 225484-7		Sample Date 2025-05-09 06:17	
Sample Description 105 Initial		Sample Matrix Drinking Water	
Analyte	Result	Units	Qual DF Detection Limit Analysis Start Date/Time Analyst Initials
Metals - Total in Water by ICP-MS			
Lead	Total	1.31	µg/L 1 0.20 May 27, 2025 07:35 FR

Reference Number 225484-8		Sample Date 2025-05-09 06:20	
Sample Description 105 Flush		Sample Matrix Drinking Water	
Analyte	Result	Units	Qual DF Detection Limit Analysis Start Date/Time Analyst Initials
Metals - Total in Water by ICP-MS			
Lead	Total	0.99	µg/L 1 0.20 May 27, 2025 07:35 FR

Reference Number 225484-9		Sample Date 2025-05-09 06:22	
Sample Description 106 Initial		Sample Matrix Drinking Water	
Analyte	Result	Units	Qual DF Detection Limit Analysis Start Date/Time Analyst Initials
Metals - Total in Water by ICP-MS			
Lead	Total	1.46	µg/L 1 0.20 May 27, 2025 07:35 FR

Reference Number 225484-10		Sample Date 2025-05-09 06:23	
Sample Description 107 Initial		Sample Matrix Drinking Water	
Analyte	Result	Units	Qual DF Detection Limit Analysis Start Date/Time Analyst Initials
Metals - Total in Water by ICP-MS			
Lead	Total	2.02	µg/L 1 0.20 May 27, 2025 07:35 FR

Reference Number 225484-11		Sample Date 2025-05-09 06:25	
Sample Description 107 Flush		Sample Matrix Drinking Water	
Analyte	Result	Units	Qual DF Detection Limit Analysis Start Date/Time Analyst Initials
Metals - Total in Water by ICP-MS			
Lead	Total	0.32	µg/L 1 0.20 May 27, 2025 07:35 FR

Reference Number 225484-12		Sample Date 2025-05-09 06:28	
Sample Description 108 Initial		Sample Matrix Drinking Water	
Analyte	Result	Units	Qual DF Detection Limit Analysis Start Date/Time Analyst Initials
Metals - Total in Water by ICP-MS			
Lead	Total	<0.20	µg/L 1 0.20 May 27, 2025 07:35 FR

**Analytical Report**

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077 Attn: Accounts Payable Sampled By: Company:	Project ID:  Project Name: Project Location: LSD: P.O.: Proj. Acct. code:	IFA LIF: Area Five Agency Rochester Head Start  IFA Lead in Facilities IFA Lead in Facilities	Lot ID: <b>225484</b> Control Number: Date Received: May 13, 2025 Date Reported: May 28, 2025 Report Number: 328038 Report Type: Final Report
---	---	--	--

Reference Number 225484-13

Sample Date 2025-05-09 06:30

Sample Description 108 Flush

Sample Matrix Drinking Water

Analyte	Result	Units	Qual	DF	Detection Limit	Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>							
Lead	Total	0.21	µg/L	1	0.20	May 27, 2025 07:35	FR

Approved by:

Megan Krauskopf  
Senior Project Manager

Data have been validated by Analytical Quality Control and Element's Integrated Data Validation System (IDVS).

Generation and distribution of the report, and approval by the digitized signature above, are performed through a secure and controlled automatic process.

## Methodology and Notes

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077 Attn: Accounts Payable Sampled By: Company:	Project ID: IFA LIF: Area Five Agency Rochester Head Start Project Name: Project Location: LSD: P.O.: IFA Lead in Facilities Proj. Acct. code: IFA Lead in Facilities	Lot ID: <b>225484</b> Control Number: Date Received: May 13, 2025 Date Reported: May 28, 2025 Report Number: 328038 Report Type: Final Report
---	--	--

## Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
Metals ICP-MS Total in water	EPA	Trace Elements in Waters and Wastes by Inductively Coupled Plasma-Mass Spectrometry, E200.8	May 27, 2025	Fort Wayne

## References

EPA United States Environmental Protection Agency

Please direct any inquiries regarding this report to our Client Services group.

Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.



Element  
Suite 100, 328 Ley Road  
Fort Wayne, Indiana  
46825, United States

T: +1 (260) 471-7000  
E: Info.FortWayne@element.com  
W: www.element.com

## Report Transmission Cover Page

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: IFA LIF: Area Five Agency Rochester Head Start	Lot ID: <b>225484</b>
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By:	Project Location:	Date Received: May 13, 2025
Company:	LSD:	Date Reported: May 28, 2025
	P.O.:	Report Number: 328038
	Proj. Acct. code: IFA Lead in Facilities	Report Type: Final Report

Contact	Company	Address
Aija Putelis	120 Water Audit	PO Box 604 ZIONSVILLE, IN 46077 Phone: (317) 586-1663 Fax: Email: aija.putelis@120water.com
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email - Merge	PDF	COC / Test Report
Megan Krauskopf	120 Water Audit	Fort Wayne, IN Phone: (260) 471-7000 Fax: Email: megan.krauskopf@element.com
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email	Standard Crosstab Without Tabs	Test Report
Results 120wateraudit	120 Water Audit	PO Box 604 ZIONSVILLE, IN 46077 Phone: (000) 000-0000 Fax: Email: results@120water.com
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email - Merge	PDF	COC / Test Report
Support	120 Water Audit	PO Box 604 ZIONSVILLE, IN 46077 Phone: (317) 331-3030 Fax: Email: sampling@120water.com
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>
Email - Merge	PDF	COC / Test Report

The information contained on this and all other pages transmitted, is intended for the addressee only and is considered confidential.  
If the reader is not the intended recipient, you are hereby notified that any use, dissemination, distribution or copy of this transmission is strictly prohibited.  
If you receive this transmission by error, or if this transmission is not satisfactory, please notify us by telephone.



225484

# Chain of Custody

Facility Name: Area Five Agency Rochester Head Start  
Facility ID: N/A  
Sample Event ID: 12941  
Account ID: 1-IFA LIF

**Chain of Custody (CoC) Instructions:** The CoC is an official record that accounts for your water samples and must be filled out. You can either collect samples with your 120Water account or by using this form. If you collect samples within your 120Water account, simply fill out section 1 and use return to lab shipping label included in kit and drop kit off at post office. If you use this form to collect samples, fill out both sections 1 and 2, make sure to write down the time you collected each sample and then use return to lab shipping label included in kit and drop kit off at post office. Have questions? Call 800.674.7961 or email [support@120water.com](mailto:support@120water.com)

## SECTION 1 MUST BE COMPLETED (even if you collect samples with your 120Water account)

Sampling Date (MM/DD/YYYY):	05/09/2025	Sample Collector's Email:	Jhole@areafive.com
Sample Collector(s) Name (s) (Please Print):	John Hole	Sample Collector's Phone:	574-343-0214
Sample Collector(s) Signature:	<i>[Signature]</i>	When was water last used in the building?	DATE: 5/8/25 TIME: 3:30pm

Did you collect samples within your 120Water account? ☒ YES ☐ NO, I will use this form

\*\*\*\*\*

## SECTION 2 (NEXT PAGE) MUST BE COMPLETED IF YOU USE THIS FORM TO COLLECT SAMPLES

If you use this form to collect samples (instead of collecting within the 120Water platform) you must write the time each sample was collected in Section 2.

RECEIVED IN LAB BY: <i>[Signature]</i>		DATE: 5-13-25	TIME: 14:35
WORK ORDER:		Lab Reporting: Email EDD to <a href="mailto:results@120water.com">results@120water.com</a>	
Matrix: DW-Lead		Analyte: Total Lead	
Sample Type: Grab			

21.3°C  
IR-023

225484

## Section 2 (Starting Here) Must be Completed if you use this Form to Collect Samples -

Sample Code	Fixture Code	Sample Type	Location	Location Description	Fixture Type	Time Sample Collected	Notes
477757	101	Initial	Classroom 2	Bathroom in classroom 2	Faucet, Cold		
477758	102	Initial	Classroom 2	Faucet in classroom 2	Faucet, Cold		
477759	102	Flush	Classroom 2	Faucet in classroom 2	Faucet, Cold		
477760	103	Initial	Classroom 1	Faucet in classroom 1	Faucet, Cold		
477761	103	Flush	Classroom 1	Faucet in classroom 1	Faucet, Cold		
477762	104	Initial	Classroom 1	Faucet in bathroom in classroom 1	Faucet, Cold		
477763	105	Initial	Outside classroom 1	Drinking fountain outside classroom 1	Drinking Water Fountain		
477764	105	Flush	Outside classroom 1	Drinking fountain outside classroom 1	Drinking Water Fountain		
477765	106	Initial	Kitchen	Kitchen faucet on the left side of sink	Faucet, Cold		
477766	107	Initial	Kitchen	Kitchen faucet on the right side of sink	Faucet, Cold		
477767	107	Flush	Kitchen	Kitchen faucet on the right side of sink	Faucet, Cold		



225484

Section 2 (Starting Here) Must be Completed if you use this Form to Collect Samples -							
Sample Code	Fixture Code	Sample Type	Location	Location Description	Fixture Type	Time Sample Collected	Notes
477768	108	Initial	Big Room	Drinking faucet by desks in the big room	Drinking Water Fountain		
477769	108	Flush	Big Room	Drinking faucet by desks in the big room	Drinking Water Fountain		